# Building picture/s

# ENERGY AUDIT CONDITIONAL GRANT REPORT FOR Building Name

Prepared By

Company logo

Auditor Name and Address

Client logo

**Client Name and Address** 

Under



SUSTAINABLE ENERGY DEVELOPMENT AUTHORITY MALAYSIA

# CONFIDENTIALITY

This document contains information for the sole perusal of .....

# DISCLAIMER

XXXXX. has no personal or financial interest in supplying or installing equipment for this document.

# **Table of Contents**

Та	Table of Contentsii							
1	1 EXECUTIVE SUMMARY							
2	2 INTRODUCTION							
	2.1	Objective4						
	2.2	Methodology4						
	2.3	Type of Energy Audit and Process5						
	2.4	Scope of work5						
	2.5	Time Schedule and Audit Framework5						
	2.6	Energy Audit Equipment5						
3	ENE	RGY MANAGEMENT SYSTEM REVIEW6						
	3.1	Policy and targets						
	3.2	Energy data, documentation and monitoring6						
	3.3	Compliance towards regulations6						
	3.4	Energy management team6						
	3.5	Energy audit team						
	3.6	Energy Management Matrix6						
	3.7	Operation and Maintenance System Review7						
4	BUII	DING DESCRIPTION						
	4.1	General Description and Operation Hours8						
	4.2	Building Orientation and footprint8						
	4.3	Building Envelope						
	4.4	Daylighting opportunities						
	4.5	Natural ventilation						
	4.6	Ceiling – height, material and colour10						
	4.7	Floor material and colour10						
	4.8	Landscaping10						
5	ELE	CTRICAL SUPPLY INFORMATION11						
	5.1	Tariff11						
	5.2	Historical Energy Consumption11						

6 I	ENERGY CONSUMPTION INFORMATION AND ANALYSIS – ELECTRICAL	12
6.1	System Description	12
6.2	Load Profile – Electrical	12
6.3	Energy load survey and site evaluation for transformers and UPS system	13
6.4	Observations and Findings	13
7 I	ENERGY CONSUMPTION INFORMATION AND ANALYSIS – CHILLED WATER SYSTEM	14
7.1	System description	14
7.2	Load Profile – Thermal/Chilled Water	14
7.3	Observations and Findings	16
8 I	ENERGY CONSUMPTION INFORMATION AND ANALYSIS - AIR CONDITIONING AND MECHANICAL	
VENT	ILATION SYSTEM	17
8.1	System Description	17
8.2	Observations and Findings	19
9 I	ENERGY CONSUMPTION INFORMATION AND ANALYSIS - LIGHTING SYSTEM	20
9.1	System Description	20
9.2	Observations and Findings	20
10	ENERGY CONSUMPTION INFORMATION AND ANALYSIS - VERTICAL TRANSPORT (LIFTS AND	
ESCA	LATORS)	21
10.	1 System Description	21
10.	2 Observations and Findings	21
11	ENERGY CONSUMPTION INFORMATION AND ANALYSIS - GENERAL EQUIPMENT AND PLUG	
LOAD	S 22	
11.	1 Observations and Findings	22
12	ENERGY CONSUMPTION INFORMATION AND ANALYSIS - BUILDING CONTROL SYSTEM	23
12.	1 System Description	23
12.	2 Observations and Findings	24
13	LOAD APPORTIONING AND ENERGY INDEX	25
14	ENERGY SAVING MEASURES	27
15	ENERGY SAVING MEASUREMENT AND VERIFICATION	30
16	CONCLUSION	31
17	VERIFICATION	32

iv

# **1 EXECUTIVE SUMMARY**

Objectives, scope and type of audit.

Key systems and equipment audited.



#### Describe chart



Describe graph

No	ESM	ESM			Estimated Investment	Simple Payback Period / ROI	Estimated Carbon Reduction
		Energy (% )	Energy (KWh)	Cost (RM)	RM	Years	Tonne/yr
	No Cost						
1.	Decommissioning all non- critical ACSU units when chiller plant has been retrofitted	Calculate from baseline	577,587.64	306,121.45	-	0.1	-
2.	Delamping		63,825.41	26,577.99	-	0.1	44.29
	Low/Medium Cost						
1.	Transform Electricity Tariff (TNB) from C1 to C1-OPTR			J- 191 21	12,000	0.36	-
2	Retrofit FL 36W to LED 20W		6 ,28, 32	07,288.30	116,820	4.76	51.37
	High Cost						
1.	Retrofit High Efficiency AHU with Valve Actuator		305,746.18	111,567.31	965,000	8.68	233.41
2.							
	TOTAL	XX	XXX,XXX	XXX,XXX	XXX,XXX	Х	XXX

#### Brief summarized description of energy saving recommendations and their cost-effectiveness



Describe chart

Table xx: Overall potential saving

Not Floor Aroa	Baselin	e (year)	After ESM Im					
Net Floor Area	Energy	BEI	Energy	BEI	Reduction			
m²	kWh/yr	kWh/m²/yr	l⊘h/yr	kWh/m²/yr				
27,470.86	5,655,205	205.86	8,968,302.45	144.45	30%			
<b>_</b>								

Table xx: Carbon Emission Intensity (CEI) (kg/m<sup>2</sup>/yr)

Not Floor Aroa	CO <sub>2</sub> Base	ine (year)	After ESM Im					
Net FIOU Alea	CO <sub>2</sub> e	CEI	CO <sub>2</sub> e	CEI	Reduction			
m²	kg/yr	kg/m²/yr	∖ 🗽g/yr	kg/m²/yr				
27,470.86	3,371,633.22	122.73	2,083,851.81	75.86	<mark>38%</mark>			
50.								

Table xx: CO<sub>2</sub> Emission Reduction Assessment Scheme for GreenPASS

	Level of achievement (% of CO <sub>2</sub> e reduction)	Assessment Scheme for Existing Buildings	
(	100% Carbon Neutral	<b>~ ~ ~ ~ ~ ~ ~ ~</b>	
(	$\geq$ 70 to < 100		
(	≥ 50 to < 70	$\bigtriangledown \bigtriangledown \bigtriangledown \lor \lor \lor$	
	≥ 30 to < 50	$\bigtriangledown \bigtriangledown \checkmark \checkmark$	>
(	≥ 10 to < 30		
(	$\geq$ 1 to < 10	(	

Based on the CIDB 2012 GreenPASS assessment scheme above, the level of achievement in 38% carbon reduction is eligible for 3 diamonds certification.

# **2** INTRODUCTION

Brief explanation on functions, operation hours, occupancy rate, etc.

#### **Building Description**

Building Name:	Client name
Address:	Client address
Building Use:	Commercial and Office
In operation since:	2001

# 2.1 Objective Brief explanation

# 2.2 Methodology

**Brief explanation** 





# **2.3** Type of Energy Audit and Process Brief explanation

#### **2.4** Scope of work Brief explanation

# 2.5 Time Schedule and Audit Framework

	Indicat ors	Task Name	Duration	Work	Jan	Feb	Mar			A
1		Energy Audit Proposal for 3G3	81 days	0 hrs	V				_	
2		Preliminary Walkthrough	5 days	0 hrs						
3		Detailed Energy Audit	61 days	0 hrs	2			▽		
4		Desktop Data	5 days	0 hrs						
5	11	Field Measurement & Observation	25 days	0 hrs						
6		Data Analysis	8 days	0 hrs						
7		Load Demand	8 days	0		>				
8		Energy Saving Measures	15 de	hrs				5		
9		Report	15 .					-	_	
10		1st Draftc& Presentation	15 day	0 hrs				2		

# 2.6 Energy Audit Equipment

List of equipment

# **3 ENERGY MANAGEMENT SYSTEM REVIEW**

#### 3.1 Policy and targets

Policy declaration and brief description of action plans, targets, timeframe, roles and responsibilities

# 3.2 Energy data, documentation and monitoring

Describe the level of documentation available in the organization, policies, records, regulations, guides, training in relation to energy management

Describe monitoring of energy use procedures, energy performance indicators, effectiveness of action plans in achieving objectives and targets, evaluation of actual vs expected energy consumption – results from monitoring and measurement should be recorded

#### 3.3 Compliance towards regulations

Describe evaluation procedures in complying with legal requirements in relation to energy use and consumption, records

# 3.4 Energy management team

List names, position and role

#### 3.5 Energy audit team

List names, position and role

# 3.6 Energy Management Matrix

EM matrix may be used to determine level of energy management practiced and can be used as a guide for improvement

	Policy and Systems	Organization	Motivation	Information System.	Training and awareness	Investment
4	Formal energy /environmental policy and management system, action plan and regular review with commitment of senior management or part of corporate strategy	Energy / environmental management fully integrated into management structure. Clear delegation of responsibility for energy use	Formal and informal channels of communication regularly exploited by energy / environmental manager and staff at all levels	Comprehensive system sets targets, monitors materials and energy consumption and wastes and emissions, identifies faults, quantifies costs and savings and provides budget tracking	Marketing the value of material and energy efficiency and the performance of energy / environmental management both within the organization and outside it	Positive discrimination in favour of energy / environmental saving schemes with detailed investment appraisal of all new build and plant improvement opportunities
3	Formal energy / environmental policy but no formal management system and with no active commitment from top management	Energy / environmental manager accountable to energy committee, chaired by a member of the management board	Energy / environmental committee used as main channel together with direct contact with major users	Monitoring and targeting reports for individual premises based on sub- metering / monitoring but savings not reported effectively to users	Programme of staff training, awareness and regular publicity campaigns	Same pay back criteria as for all other investments. Cursory appraisal of new build and plant improvement opportunities
2	Unadopted / informal energy / environmental policy set by energy / environmental manager or senior departmental manager	Energy / environmental manager in post, reporting to ad-hoc committee but line management and authority unclear	Contact with major users through ad-hoc committee chaired by senior departmental manager	Monitoring and targeting reports based on supply meter / measurement data and invoice. Env / energy staff have ad- hoc involvement in budget setting	Some ad-hoc staff awareness and training	Investment using short term pay back criteria mostly
1	An unwritten set of guidelines	Energy or environmental management the part- time responsibility of	Informal contacts between engineer and a few users	Cost reporting based on invoice data. Engineer compiles	Informal contacts used to promote energy efficiency and	Only low cost measures taken

	Policy and Systems	Organization	Motivation	Information System.	Training and awareness	Investment
		someone with only limited influence or authority		reports for internal use within technical department	resource conservation	
0	No explicit policy	No energy environmental manager or any formal delegation of responsibility for env/energy use	No contact with users	No information system. No accounting for materials and energy consumption and waste	No awareness raising of energy efficiency and resource conservation	No investments in increasing environmental performance or energy efficiency in premises

# 3.7 Operation and Maintenance System Review

List scope of works involved for energy management

# **4 BUILDING DESCRIPTION**

# 4.1 General Description and Operation Hours

Describe building function, occupancy, general services provided

# 4.2 Building Orientation and footprint

# Picture/s of building – side, front, top views

Description	Gross Floor Area	Air Conditioned	Height (m)
		Area	
Client name	83,000	45,900	35 (6 floors)

#### 4.3 Building Envelope

Overall Thermal Transfer Value (OTTV) and Roof Thermal Transfer Value (RTTV)

WALL CONSTRUCTION

Types of insulation

#### Material colour

No.	Description	Thickness	U-Value
		(mm)	(W/m²K)
1	Wall		
	Cement Plaster	20	2.19
	Granite (Solar Absorption Factor, $\alpha$ =	200	2.927
	0.45, Light Grey)		
2	Fenestration		
	Laminated toughened tinted g	12	4.8
3	Roof		
	Roof Tile 🦰 🚺 🕨 🌅	20	0.6
	Reflective Foiler Filegi	50	0.035
	Asbestos Board	3	1.298

#### WINDOW TO WALL RATIO

Shading/glazing level

#### Design and operation

Wall	Total Glass	Total Façade	WWR
	Area (m²)	Area (m²)	

	North West Wall	1037.18	8938.715	0.12
	North East Wall	355.6	4108.48	0.09
	South East Wall	1027.24	8938.72	11
	South West Wall	355.60	11.9.48	0.09
· AÇ	ADE			

#### OTTV OF EACH F AÇADE

ΟΤΤΥ	ιο   νττο <u> </u> νττο <i>τ</i>		ΟΤΤΥ	Total
(North	(North	(South	(South	ΟΤΤΥ
West)	East)	East)	West)	
20.34	21.28	21.39	20.34	21.02

#### **ROOF CONSTRUCTION**

Types of insulation

# Material colour

Material	Thickness (m)	Density kg/m3	k-value W/m K	Resistance (m2K/W)
Outside air film	-		-	0.06
Roof Tile	0.02	1890	0.836	0.02
Reflective Foil &	0.05		0.035	1.43
Fibreglass				
Asbestos Board	00	720	0.108	0.03
Inside air film				0.15
e C				
Total Resist nce				1.68
U-Value				0.59

# RTTV of each roof direction

	Gross Roof Area (m2)	RTTV
Flat Roof	7599	10.5 5.1
North East	1/90	2. 44 33
North West	285	0734.93
South East	1 121	41647.44
Sout vv st	1522	21700.58
Ciote PT V	16389	14.26

- 4.4 Daylighting opportunities
- 4.5 Natural ventilation
- 4.6 Ceiling height, material and colour
- 4.7 Floor material and colour
- 4.8 Landscaping

# **5** ELECTRICAL SUPPLY INFORMATION

# 5.1 Tariff

Describe tariff system used

Year	Energy Rate (RM/kWh)	Maximum Demand Rate (RM/kW)
June 2011 – Dec 2013	RM0.312	RM25.90
Jan 2014- present	RM0.365	RM30.30

# 5.2 Historical Energy Consumption

#### Describe energy consumption and cost



#### Describe energy consumption, maximum demand and costs



Describe load factor and evaluation

# 6 ENERGY CONSUMPTION INFORMATION AND ANALYSIS – ELECTRICAL

#### 6.1 System Description

Describe system



electrical schematic diagram

#### 6.2 Load Profile – Electrical

Describe load profile and observations

Highlight baseload readings



# 6.3 Energy load survey and site evaluation for transformers and UPS system

<b>Describe load</b>	loss evaluation	for transformers and	J UPS	(if any)
----------------------	-----------------	----------------------	-------	----------

Description	Tx 1	Тх 2	Тх 3	Тх 4
Average Efficiency (%)	94.37%	94.63%	94.52%	94.85%
Current Capacity (kVA)	321.65	156.86	321-30	551.88
	12.87%	0. 7%	7.65%	13.14%
Available Capacity (%)	8 13	93.73%	92.35%	86.86%
Problems Detected		Dip, swell, interruption and impulse	Interruption	Interruption and impulse

# 6.4 Observations and Findings

Describe observations and findings

# 7 ENERGY CONSUMPTION INFORMATION AND ANALYSIS – CHILLED WATER SYSTEM

#### 7.1 System description

#### Describe system

#### Air conditioning schematic diagram



# 7.2 Load Profile – Thermal/Chilled Water

Describe load profile and observations

**Cooling Load** 



#### Describe chilled water system and operation

Day	Average Load factor	Average COP
01	77%	3.7
02	82%	
03	88%	4.5
04		4.3
05	. 4%	4.8
06 💆	95%	4.9
07	94%	5.1
Overall	88%	4.5

#### Evaluate Chiller COP and System COP



7.3 Observations and Findings Describe observations and findings

# 8 ENERGY CONSUMPTION INFORMATION AND ANALYSIS - AIR CONDITIONING AND MECHANICAL VENTILATION SYSTEM

# 8.1 System Description

# Describe system/s

No	Description		Total Installed Power (kW)
		•	Main Building
1	Chilled Water Pumps	1	220kW
2	Air Handling Units	4	632.2kW
3	Fan Coil Unit	30	188kW
4	Variable Refrictra t Volume	29	100.37kW
	(VRV) Unit		
5	Ventilati Sal.	90	337.6kW
6	Cooling Terer Fan	4	200kW
7	Condenser Water Pumps	4	130kW

#### Time schedule of operations

No	Description	Quantity	Operation	Hours
			Start	Stop
			Mai	in Building
1	Chilled Water Pumps (Duty)	2	6:00am	6:00pm
	Chilled Water Pumps (Standby)	2	6:00pm	6:00am
2	Rooftop Chiller (Duty)		6:00pm	6:00am
	Rooftop Chiller (Standby) 🛛 🚬 🌱		6:00am	6:00pm
3	Air Handling Units (24hr	25	6:00am	6:00am
4	Air Handling United	21	6:30am	6:00pm
5	Fan Coil Unii (2 (hrs)	16	6:00am	6:00am
6	Fan Coil Units	14	7:00am	6:00pm
7	Variable Refrigerant Volume	28	6:00am	6:00am
	(VRV) Unit			
8	Ventilation Fans (toilets)	86	Mai	nual
9	Ventilation Fans (Fresh air)	4	6.00 a.m	6.00 p.m

# Fan Specific Power

# Describe findings

No	AHU	Air Flow Rate, m <sup>3</sup> /hr		Fan Power, W	Fan Efficiency,
		Design	Running		W/m³hr
1	AHU-L1-MO1.4	28,237	17,193	8,668	0.50
2	AHU-L1-MO1.8	34,503	33,361	9,833	0.29

No	AHU	Air Flow R	late, m <sup>3</sup> /1r	wer, W	Fan Efficiency,
		Design	an 1g		W/m°hr
3	AHU-L1-MO1.9	21-1,1	053	7,439	0.78
4	AHU-L2-MO1.1	37,3 2	2,554	9,768	0.38
5	AHU-L2 O1	30,621	10,602	8,345	0.79
6	AHU-L2-IVIC .5	36,358	30,991	15,202	0.49

# Air Change Rate (ACR) and AHU Capacity Analysis

# Describe findings

No	AHU	Capacity, Btu/hr	Air Flow Rate, m <sup>3</sup> /hr		Served Area, m <sup>2</sup>	Air Chang (A	ge Per Hour (CH)	Capacity Intensity,
			Design	Runnin		Design	Running	Btu/hr ft
1	AHU-L1-M01.9	593,688	25,269	0.539	9.2	8.5	3.2	56.9
2	AHU-L1-M01.8	812,056	34,502	13,36	1,600.9	7.0	6.8	47.1
3	AHU-L1-M01.4	665,340	6,2 2	1 192	1,077.5	8.6	5.2	57.4
4	AHU-ANX-L1A.3	535,6 +	1,824	5,853	925.2	8.1	2.1	53.8
5	AHU-L2-M01.1	220.2	37,392	25,554	1,720.3	12.8	4.9	47.5
6	AHU-L2-M01.2	236,236	36,621	10,603	1,448.8	8.3	2.4	55.4

# **Indoor Air Quality**

# Describe findings



#### Air Conditioning Room Conditions

#### **Describe findings**





8.2 Observations and Findings Describe observations and findings

# 9 ENERGY CONSUMPTION INFORMATION AND ANALYSIS - LIGHTING SYSTEM

#### 9.1 System Description

Show list of lighting types and quantity

Describe lighting system and operation

No	Description 🔦	Ormation	Hours
		1	Stop
		Ma	in Building
2	Lobby, Walkways	6:00am	6:00am
3	Offices	6:30am	6:00pm
4	Outdoor ght, g	7:00pm	7:00am
5	Dect	6:00am	6:00am
6	Car Patter (24hrs)	6:00am	6:00am

#### **Lighting Conditions**

#### Describe findings



9.2 Observations and Findings Describe observations and findings

# 10 ENERGY CONSUMPTION INFORMATION AND ANALYSIS - VERTICAL TRANSPORT (LIFTS AND ESCALATORS)

# **10.1** System Description

# Describe system and operation

Room No./ Description	Equipment Description	Rated Power [kW]	Quantity
North Lift	Lift No. 2	22	1
North Lift	Lift No. 3	22	1
South Lift	Lift No. 4	22	1
South Lift	Lift N	22	1
Main Lobby	<b>⊥</b> t ∧ _ 6	22	1
Main Lobby 为	∟íft No. 7	22	1
OKT Lift	Lift No. 8	11	1
OKT Lift	Lift No. 9	11	1
Service Lift	Lift No. 12	22	1

**10.2** Observations and Findings

Describe observations and findings

# 11 ENERGY CONSUMPTION INFORMATION AND ANALYSIS - GENERAL EQUIPMENT AND PLUG LOADS

Describe typical list of equipment used, operation hours and rated power

Summary of total energy consumption measured from instantaneous power readings

**11.1 Observations and Findings** 

Describe observations and findings

# 12 ENERGY CONSUMPTION INFORMATION AND ANALYSIS - BUILDING CONTROL SYSTEM

# **12.1** System Description

# Describe system/s

No.	Description	Qty	Monitor/control
1	СНШР		Control
2	AHU	55	Control
3	VAV	пА	Control
4	FCU	46	Control
5	VRV	56	Control
6	Lighting – Genera Are scoly	NA	Control
7	External Ligi	296	Control
8	Car Park Light🔫	NA	Monitor
9	Ventilation Fans (Main Bldg only)	138	Control

#### Describe system operations

System	Equipment	Control strategy
ACMV	AHU	<ul> <li>Fan speed is controlled by variable speed drive. Controlled variable is supply duct static pressure which is set at certain value.</li> <li>Control valve position is controlled by valve actuator. Controlled variable is supply air temperature.</li> <li>AHU operation is controlled by schedule program from BCS.</li> </ul>
	VAV	<ul> <li>VAV damper position is controlled by VAV actuator. Controlled valuable is one temperature.</li> <li>VAV positional data temperature are monitored by BC<sup>s</sup></li> </ul>
	VRV	• 1 V.V c.m. er position is controlled by VAV actuator. Controlled variable is zone temperature. VRV position and zone temperature are monitored by BCS.
	Ventilation/Fresh Air Fan	<ul> <li>Fresh air fan operation hours are controlled by schedule program from BCS.</li> <li>Speed regulation of fresh air fan is controlled by Variable speed drive. Controlled variable is static pressure which varies according to fresh air damper position to each AHU.</li> </ul>
	Chilled water pump	Chilled water pump is controlled by variable speed drive. Controlled variable is chilled water pressure differential between supply and return main.
Lighting	Indoor General Areas	Lighting operation is controlled by schedule program from BCS

# 12.2 Observations and Findings

Describe observations and findings

# **13 LOAD APPORTIONING AND ENERGY INDEX**

### Describe chart

End Use Loads	Annual Consumption (kWh)	Percentage
Cooling Energy	2,281,310.00	28%
Lighting	979987. 7	12%
General Plug Load	35104 3.	4%
Chilled Water Pumps	28 75/ 64	3%
AHU	2 85 22.14	30%
FCU and ACCU	556365.12	7%
Ventilation Fa	474451.85	6%
Rooftop Chiller	118081.65	1%
VRV	607505.74	8%
Lift	12776.99	0.2%



# **Energy Indices**

#### Describe table and charts

Building Energy Intensity Index (BEII)	kWh/m2
Lighting Energy Intensity Index (LEII)	kWh/m2
Air Conditioning Energy Intensity Index (ACEII)	kWh/m2
Building Power Baseload	kW

Lighting Power Density	W/m2
Air Conditioning Power Density	W/m2
Equipment Power Density	W/m2
Baseload Power Index	W/m2



# **14 ENERGY SAVING MEASURES**

Explain each esm in detail showing basis of calculations and assumptions made

#### No low cost measure

Findings

Energy Saving Recommendation/Measure

Potential Annual Cost and Savings

Estimated Investment Cost

**ROI/SPP** 

#### **Medium cost measure**

Findings

Energy Saving Recommendation/Measure

Potential Annual Cost and Savings

Estimated Investment Cost

**ROI/SPP** 

#### High cost measure

Findings Energy Saving Recommendation/Measure Potential Annual Cost and Savings

Estimated Investment Cost

ROI/SPP

# Summary ESM table

No	ESM	Estimated Saving			Estimated Investment	Simple Payback Period / ROI	Estimated Carbon Reduction
		Energy (% )	Energy (KWh)	Cost (RM)	RM	Years	Tonne/yr
	No Cost						
1.	Decommissioning all non- critical ACSU units when chiller plant has been retrofitted	Calculate from baseline	577,587.64	306,121.45	-	0.1	-
2.	De-lamping		63,825.41	6,57 .9	-	0.1	44.29
	Low/Medium Cost						
1.	Transform Electricity Tariff (TNB) from C1 to C1-OPTR			33,196.31	12,000	0.36	-
2	Retrofit FL 36W to LED 20W		57,288.32	67,288.30	116,820	4.76	51.37
		50					
	High Cost						
1.	Retrofit High Efficiency AHU with Valve Actuator		305,746.18	111,567.31	965,000	8.68	233.41
2.							
	TOTAL	XX	XXX,XXX	XXX,XXX	XXX,XXX	Х	XXX

- Financing options/Government Incentives available
- Guides on how to implement proposed energy saving measures

# • Proposed action plan and estimated time required to implement each measure :

	Year	Energy Consumption (kWh/yr)	% reduction of Energy Consumption	BEI (kWh/m² /year)	Initiatives -ESM	Investment Cost (RM)	Gross Saving / Net Saving (RM)
Oct (E	-Sep 2017 Baseline)	5,655,207.00					
					Target		
5	<b>Q1</b> (Oct-Dec 2017)	5,275.700.35			Low Cost Measures 1. Transform Electricity Tariff (TNB) from C1 to C1-OPTR	12,000	33,196.31
Year 1 Implementatio	<b>Q2-Q3</b> (Jan-Jun 2018)		6.71		No Cost Measures 1. Derectorissi, ling "Cont-critical A U unit within chiller plant has be cretoritted	-	306,121.4 5
	<b>Q4</b> (Jul-Sep 2018)		ςC		No Cost Measures 1. De-lamping 2xxx		26,577.99
io	<b>Q1</b> (Oct-Dec 2018)				<ul> <li>Low Cost Measures</li> <li>1. EE Awareness campaign – eco mode PC / switch-off when not using appliances/lunch time</li> </ul>	XX,XXX	XXX,XXX
Year 2 nplementat	<b>Q2-Q3</b> (Jan-Jun 2019)	4,748,130.15	10		Medium Cost Measures 1. Retrofit FL 36W to LED 20W	XX,XXX	67,288.30
	<b>Q4</b> (Jul-Sep 2019)				Medium Cost Measures 1. XXXXXXXXX	XX,XXX	XX,XXX
Year 3 Implementation	<b>Q1-Q4</b> (Oct 2019 – Sep 2020)	4,083,391.90	14		High Cost Measures 1. Retrofit High Efficiency AHU with Valve Actuator	XXX,XXX	XXX,XXX

# **15 ENERGY SAVING MEASUREMENT AND VERIFICATION**

Types of baseline data:

- Past year bills
- Measurements

Measurement and Calculation methods

Measurement & Verification methods

# **16 CONCLUSION**

#### conclusion



Level of achievement (% of CO <sub>2</sub> e reduction)	Assessment Scheme for Existing Buildings
100% Carbon Neutral	<b>~ ~ ~ ~ ~ ~ </b>
$\geq$ 70 to < 100	
≥ 50 to < 70	<b>W W W</b>
≥ 30 to < 50	
≥ 10 to < 30	<b>W W</b>
$\geq$ 1 to < 10	

Construction Industry Standard 2012 CIS20:2012 GreenPASS assessment scheme

# **17 VERIFICATION**

This Energy Audit Report is		
prepared by:	checked by:	received by SEDA Malaysia
Name:	Name:	Name:
Position:	Position:	Position:
	Data	Data
Date:	Date:	Date: